



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

October 26, 2011

DESIGN HOMES, INC.  
KURT SMITH  
600 N MARQUETTE RD  
PO BOX 239  
PRAIRIE DU CHIEN WI 53821

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: DESIGN HOMES, INC.  
Product Name: 36 X28 2 STORY  
Model Number(s): NONE  
Product File No: 20110325

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2017.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 30 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on November 16, 2006 under product file number 20060457.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060457.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov